EHS Laboratories

Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Metals in Drinking Water Analysis Report

Client: Paul D Sakson Associates Inc
P.O. Box 154
Leonardo, NJ 07737-0154

Report Number: 22-01-00894

Received Date: 01/10/2022
Reported Date: 01/12/2022

Project/Test Address: Kidzland; 777 Washington Rd; Parlin, NJ

Client Number:
201717

Laboratory Results

Fax Number:
855-710-7460

Lab Sample Number	Client Sample Number	Collection Location	Analysis Date/Time	Analyte	Concentration ppb (ug/L)	Narrative ID
22-01-00894-001	1	HAND WASH SINK OUTSIDE BR	01/11/2022	Copper (Cu)	102	
			01/11/2022	Lead (Pb)	1.33	
22-01-00894-002	2	CLASSROOM WALL SINK	01/11/2022	Copper (Cu)	350	
			01/11/2022	Lead (Pb)	<1.00	
22-01-00894-003	3	KITCHEN SINK	01/11/2022	Copper (Cu)	108	
			01/11/2022	Lead (Pb)	<1.00	

Environmental Hazards Services, L.L.C

Client Number: 201717

Project/Test Address: Kidzland; 777 Washington Rd; Parlin, NJ

Report Number: 22-01-00894

Lab Sample Number	Client Sample Number	Collection Location	Analysis Date/Time	Analyte	Concentration ppb (ug/L)	Narrative ID

Analyst: Ailea Cabatbat

Method: EPA 200.8

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb for Lead and 5 ppb for Copper.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb and for Copper is 1300 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L = microgram per liter ppb = parts per billion

EHS Laboratories™

ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart ® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com
7469 Whitepine Rd, N. Chesterfield, VA 23237-2261

22-01-00894

Due Date:
01/24/2022
(Monday)
AE

Client Name: Paul D. Sakson Associates, Inc. Account #: 201717

Address: PO Box 154

City/State/Zip: Leonardo NJ 07737-0154

Phone: (732) 230-7510

Email Address: p.sakson@paulsakson.com

Project Name/ Number: Kidzland

Collection Address: 777 Washington Rd (Required) City/State/Zip: Parlin NJ (Required)

Approx. Age Of Property: _____ Collected By: Brenna Ilg

Water Source: (Check One) Public x or Well _____ Well Tag # (if applicable): not applicable

Turn-Around Time: x 10 Days ____ 5 Days ____ 3 Days ____ 2 Days ____ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte Pb	Analyte Cu
1	1	Hand Wash Sink Outside BR	1/6/22	8:00 (AM) / PM	✓	✓
2	2	Classroom Wall Sink	1/6/22	8:02 (AM) / PM	✓	✓
3	3	Kitchen Sink	1/6/22	8:04 (AM) / PM	✓	✓
4	4			AM / PM		
5	5			AM / PM		
6	6			AM / PM		
7	7			AM / PM		
8	8			AM / PM		
9	9			AM / PM		
10	10			AM / PM		
11	11			AM / PM		
12	12			AM / PM		
13	13			AM / PM		
14	14			AM / PM		
15	15			AM / PM		

Released by: Brenna Ilg Signature: Date/Time: 1/6/22 10:30 AM

Received by: Signature: Date/Time: 1/10/22 1245